

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Pumps (Submersible monoblock multistage centrifugal pump for water supply)

Name and address of the applicant

ESPA 2025 S.L.
Ctra. Mieres s/n,
17820 BANYOLES (GIRONA), Spain

Name and address of the manufacturer

same as applicant

Name and address of the factory

same as applicant

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

220 V~, 60 Hz, 750 W to 2600 W, Class I, IP68

Trademark (if any)

ESPA

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

ACUARIA07 3M A N C15,
ACUARIA07S 2M 220 60 14793/STD,
ACUARIA07S 2M A 220 60 14793/STD,
ACUARIA07S 3M 220 60 14793/STD,
ACUARIA07S 3M A 220 60 14793/STD,
ACUARIA07S 3M A 220 60 14797/ESP,
ACUARIA07S 4M 220 60 14793/STD,
ACUARIA07S 4M A 220 60 14793/STD,
ACUARIA17 3M SP2 220 60 10590/ESP,
ACUARIA17 3M A 220 60 320/STD,
ACUARIA17 4M 220 60 320/STD,
ACUARIA17 4M A 220 60 320/STD,
ACUARIA17 5M 220 60 320/STD,
ACUARIA27 3M 220 60 324/STD,
ACUARIA27 3M A 220 60 324/STD,
ACUARIA27 4M 220 60 324/STD,
ACUARIA27 4M A SP1 220 60 10597/ESP

Additional information (if necessary may also be reported on page 2)

Re-issue of BE-8783 dated 2019-05-03 due to technical change.
Addition/modification of types designations. For details refer to test report.
 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60335-1:2010(ed. 5.0) + corrigendum 2010 + Corrigendum 2 - April 2011 + A1:2013 + A2:2016, IEC 60335-2-41:2012(ed. 4.0)
National Differences:
Saudi Arabia (SA) National Deviations

As shown in the Test Report Ref. No. which forms part of this Certificate

2118/1038, 2118/1038-AM1

This CB Test Certificate is issued by the National Certification Body

SGS Belgium NV - Division SGS CEBEC
Riverside Business Park
Avenue Internationalelaan 55, Building D
B-1070 Brussels, Belgium




Date: 03/06/2020

Signature: Daniel Arranz

Name and address of the factories:

Additional information:

Model (s)	ACUARIA07S 2M 220 60 14793/STD ACUARIA07S 2M A 220 60 14793/STD ACUARIA07S 3M 220 60 14793/STD ACUARIA07S 3M A 220 60 14793/STD ACUARIA07S 3M A 220 60 14797/ESP ACUARIA07S 4M 220 60 14793/STD ACUARIA07S 4M A 220 60 14793/STD	ACUARIA17 3M SP2 220 60 10590/ESP ACUARIA17 3M A 220 60 320/STD ACUARIA17 4M 220 60 320/STD ACUARIA17 4M A 220 60 320/STD ACUARIA17 5M 220 60 320/STD	ACUARIA27 3M 220 60 324/STD ACUARIA27 3M A 220 60 324/STD ACUARIA27 4M 220 60 324/STD ACUARIA27 4M A SP1 220 60 10597/ESP
Rated voltage	220V AC 60Hz	220V AC 60Hz	220V AC 60Hz
Rated power	750W – 1400W	1600W – 2800W	1800W – 2600W
Protection class	F	F	F
Protection degree	68	68	68
Maximum temperature	40°C	40°C	40°C
Throughput capacity	(10-80) l/min	(20-90) l/min	(30-120) l/min
Minimum height	10 m – 30 m	25 m – 93 m	25 m – 65 m
Maximum height	35 m – 69 m	60 m – 96 m	51 m – 68 m

SGS Belgium NV - Division SGS CEBEC
Riverside Business Park
Avenue Internationale/laan 55, Building D
B-1070 Brussels, Belgium



Date: 03/06/2020

Signature: Daniel Arranz